

ANALYSIS CERTIFICATE N. 17/0980

pag. 1 di 1

ISSUED ON 12/05/17	SAMPLE NUMBER 63215	ANALYSIS STARTING DATE 08/05/17
CONSIGNED BY THE MANUFACTURER	SAMPLE TAKEN ON 05/05/17	ANALYSIS COMPLETED ON 12/05/17
MANUFACTURER BAYLAN WATER METERS Baylan Olcu Aletleri San Tic Ltd Sti A.O.S.B. 10032 Sk. No:16; Cigli/IZMIR - TURKEY		LEGISLATIVE REFERENCE Italian Health's Ministry DM 6 aprile 2004, n. 174
SAMPLE TYPE WATER METERS TK (1C-1P-1S-2-2P-2S-3C-3P-3S-4C-4P-4S-5C-5S-7C-7S-8-12-13-21-22-23-24-25-26-26S-27-28-29) and all of their internal components Transfer test with distillate water at 40 °C for 24 hours		

Parameter	Measured value (ppm)	Limit required by law (ppm)	Method
Global migration	10,8	50	Italian Health's Ministry DM 6 aprile 2004, n. 174

CONCLUSION

With reference to global migration, the analyzed manufactured item complies with the provisions of Italian Health's Ministry DM 6 aprile 2004, n. 174 and is therefore suited to come into contact with drinking water

This analysis certificate cannot be reproduced even partially
The results reported in this certificate represent only the analysed sample
Samples will be kept in the laboratory for 3 days except different prescriptions
The Director of the Laboratory (Dott. Chim. Secco Renato)

